



1605-6128-WOL1

May 16, 2016

Bill Johnson
Sky Park Santa's Village
P.O. Box 369
Sky Forest, California 92385

SUBJECT: SEPTIC SYSTEM FOR SKY PARK SANTA'S VILLAGE, LOCATED AT 28950 CA-18, SKY FOREST, CALIFORNIA, ASSESSOR'S PARCEL NUMBER 0332-212-02-0000, SAN BERNARDINO COUNTY.

Dear Mr. Johnson:

Pursuant to your request we have visited the above subject site. Please be informed of the following:

1. The proposed septic system is for a seasonal campground bathroom facility.
2. The leach line area is gently sloping, well covered with local vegetation, with slightly silty sand which was firm and unyielding at the time of our visit. No apparent geological hazards were observed.
3. Based on our site inspection and review of proposed project plans it is our opinion and belief that the installation of the proposed septic system would not adversely affect the stability of the area and would not have any negative effect on the surrounding environment.
4. The septic system may be installed as proposed. All Engineer's recommendations shall be followed during installation.

If you have any questions or if we may be of further assistance, please contact our office at your convenience. This opportunity to be of service to you is greatly appreciated.

Respectfully submitted,

FOR ARCH ENGINEERING, INC.

By Fred Jaleh, PhD, P.E.

FJ:bp



By Kevin Clark, P.G.

